

Mt. Vista-Dungeness Golf Course

Is my water safe?

We are pleased to present this year's Annual Water Quality Report (Consumer Confidence Report) as required by the Safe Drinking Water Act (SDWA). This report is designed to provide details about where your water comes from, what it contains, and how it compares to standards set by regulatory agencies. This report is a snapshot of last year's water quality. We are committed to providing you with information because informed customers are our best allies.

Do I need to take special precautions?

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. EPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Water Drinking Hotline (800-426-4791).

Where does my water come from?

Mt. Vista – Cedars at Dungeness Golf Course are served by two ground water wells, Well #3 (WL-03) is the primary, and Well #2 (WL-02) is the secondary, standby well and used mostly for irrigation. Well WL-03 is 565 feet deep and was drilled in 1998. Well WL-02 is 241 feet deep and was drilled in 1991.

Source water assessment and its availability

There is no source water assessment at this time.

Why are there contaminants in my drinking water?

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that

water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the Environmental Protection Agency's (EPA) Safe Drinking Water Hotline (800-426-4791). The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity:

microbial contaminants, such as viruses and bacteria, that may come from sewage treatment plants, septic systems, agricultural livestock operations, and wildlife; inorganic contaminants, such as salts and metals, which can be naturally occurring or result from urban stormwater runoff, industrial, or domestic wastewater discharges, oil and gas production, mining, or farming; pesticides and herbicides, which may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses; organic Chemical Contaminants, including synthetic and volatile organic chemicals, which are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, and septic systems; and radioactive contaminants, which can be naturally occurring or be the result of oil and gas production and mining activities. In order to ensure that tap water is safe to drink, EPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. Food and Drug Administration (FDA) regulations establish limits for contaminants in bottled water which must provide the same protection for public health.

How can I get involved?

For questions or concerns please contact the Jamestown S'Klallam Tribe's Utility Manager- Ilan Jones at 360-477-8673 or email at ijones@jamestowntribe.org

Description of Water Treatment Process

Your water is treated by disinfection. Disinfection involves the addition of chlorine or other disinfectant to kill dangerous bacteria and microorganisms that may be in the water. Disinfection is considered to be one of the major public health advances of the 20th century.

Cross Connection Control Survey

The purpose of this survey is to determine whether a cross-connection may exist at your home or business. A cross connection is an unprotected or improper connection to a public water distribution system that may cause contamination or pollution to enter the system. We are responsible for enforcing cross-connection control regulations and

insuring that no contaminants can, under any flow conditions, enter the distribution system. If you have any of the devices listed below please contact us so that we can discuss the issue, and if needed, survey your connection and assist you in isolating it if that is necessary.

- Boiler/ Radiant heater (water heaters not included)
- Underground lawn sprinkler system
- Pool or hot tub (whirlpool tubs not included)
- Additional source(s) of water on the property
- Decorative pond
- Watering trough

Source Water Protection Tips

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water source in several ways:

- Eliminate excess use of lawn and garden fertilizers and pesticides - they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources or consider connecting to a public water system.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization in your community and volunteer to help. If there are no active groups, consider starting one. Use EPA's Adopt Your Watershed to locate groups in your community, or visit the Watershed Information Network's How to Start a Watershed Team.
- Organize a storm drain stenciling project with your local government or water supplier. Stencil a message next to the street drain reminding people "Dump No Waste - Drains to River" or "Protect Your Water." Produce and distribute a flyer for households to remind residents that storm drains dump directly into your local water body.

Monitoring and reporting of compliance data violations

We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. Because of this failure, we cannot be sure of the quality of our drinking water during the period indicated.

Additional Information for Lead

The system inventory does not include lead service lines.

The Mt.Vista water system was determined to be free of lead service lines, galvanized requiring replacement lines, and unknown services lines through a combination of exploratory excavation and existing records.

The following link can be used to access inventory information -
<https://jamestowntribe.org/announcements/mt-vista-dungeness-golf>.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. MT. VISTA - DUNGENESS GOLF COURSE is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact MT. VISTA - DUNGENESS GOLF COURSE (Public Watersystem Id: 105388889) by calling 360-681-4627 or emailing IJONES@JAMESTOWNTRIBE.ORG. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>.

Water Quality Data Table

In order to ensure that tap water is safe to drink, EPA prescribes regulations which limit the amount of contaminants in water provided by public water systems. The table below lists all of the drinking water contaminants that we detected during the calendar year of this report. Although many more contaminants were tested, only those substances listed below were found in your water. All sources of drinking water contain some naturally occurring contaminants. At low levels, these substances are generally not harmful in our drinking water. Removing all contaminants would be extremely expensive, and in most

cases, would not provide increased protection of public health. A few naturally occurring minerals may actually improve the taste of drinking water and have nutritional value at low levels. Unless otherwise noted, the data presented in this table is from testing done in the calendar year of the report. The EPA or the State requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not vary significantly from year to year, or the system is not considered vulnerable to this type of contamination. As such, some of our data, though representative, may be more than one year old. In this table you will find terms and abbreviations that might not be familiar to you. To help you better understand these terms, we have provided the definitions below the table.

Contaminants	MCLG or MRDLG	MCL, TT, or MRDL	Detect In Your Water	Range		Sample Date	Violation	Typical Source	
				Low	High				
Disinfectants & Disinfection By-Products									
(There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants)									
Chlorine (as Cl2) (ppm)	4	4	1.1	0.9	1.1	2025	No	Water additive used to control microbes	
Inorganic Contaminants									
Arsenic (ppb)	00	10	2.8	1.7	2.8	2025	No	Erosion of natural deposits; Runoff from orchards; Runoff from glass and electronics production wastes	
Radioactive Contaminants									
Radium (combined 226/228) (pCi/L)	00	5	0.0705	0.0705	0.0705	2025	No	Erosion of natural deposits	
Contaminants	MCLG	AL	Your Water	Range		# Samples Exceeding AL	Sample Date	Exceeds AL	Typical Source
				Low	High				
Inorganic Contaminants									
Copper - action level at consumer taps (ppm)	1.3	1.3	0.12	0.03	0.14	0	2024	No	Corrosion of household plumbing systems; Erosion of natural deposits

Violations and Exceedances

Additional Contaminants

In an effort to insure the safest water possible the State has required us to monitor some contaminants not required by Federal regulations. Of those contaminants only the ones listed below were found in your water.

Contaminants	State MCL	Your Water	Violation	Explanation and Comment
Carbofuran	NA	NA	Yes	We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. Repeat samples were taken in early 2026 and came back as satisfactory.
Combined Radium 226/228	NA	NA	No	We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. In this instance, our sample bottle broke in transit to the sub lab and the main lab notified us after it was too late to resample.
Dibromochloropropane (DBCP)	NA	NA	No	We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. Subsequent samples have been taken and are awaiting results from the lab.
Diquat	NA	NA	No	We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. Repeat samples were taken in early 2026 and came back as satisfactory.
Edothall	NA	NA	No	We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an

Contaminants	State MCL	Your Water	Violation	Explanation and Comment
				accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. Repeat samples were taken in early 2026 and came back as satisfactory.
Ethylene Dibromide	NA	NA	Yes	We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. Subsequent samples have been taken and are awaiting results from the lab.
Glyphosate	NA	NA	Yes	We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. Repeat samples were taken in early 2026 and came back as satisfactory.
Lead and Copper Rule	NA	NA	No	We failed to provide the results of lead tap water monitoring to the consumers at the location water was tested. These were supposed to be provided no later than 30 days after learning the results. The notices were eventually delivered albeit after the 30 deadline.
Oxyamyl (Vydate)	NA	NA	Yes	We failed to test our drinking water for the contaminant and period indicated. Water samples were taken during this period and delivered to an accredited laboratory. The laboratory failed to run the tests properly or at all before the reporting period was over. Repeat samples were taken in early 2026 and came back as satisfactory.

Unit Descriptions	
Term	Definition
ppm	ppm: parts per million, or milligrams per liter (mg/L)
ppb	ppb: parts per billion, or micrograms per liter (µg/L)
pCi/L	pCi/L: picocuries per liter (a measure of radioactivity)
NA	NA: not applicable
ND	ND: Not detected
NR	NR: Monitoring not required, but recommended.

Important Drinking Water Definitions	
Term	Definition
MCLG	MCLG: Maximum Contaminant Level Goal: The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
MCL	MCL: Maximum Contaminant Level: The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
TT	TT: Treatment Technique: A required process intended to reduce the level of a contaminant in drinking water.
AL	AL: Action Level: The concentration of a contaminant which, if exceeded, triggers treatment or other requirements which a water system must follow.
Variances and Exemptions	Variances and Exemptions: State or EPA permission not to meet an MCL or a treatment technique under certain conditions.
MRDLG	MRDLG: Maximum residual disinfection level goal. The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
MRDL	MRDL: Maximum residual disinfectant level. The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.
MNR	MNR: Monitored Not Regulated
MPL	MPL: State Assigned Maximum Permissible Level
90th Percentile	Compliance with the lead and copper action levels is based on the 90th percentile lead and copper levels. This means that the concentration of lead and copper must be less than or equal to the action level in at least 90% of the samples collected.

For more information please contact:

Contact Name: JONES, ILAN
Address: 1033 OLD BLYN HWY
SEQUIM, WA 98382
Phone: 360-477-8673

Email: ijones@jamestowntribe.org